

## TEST REPORT

DATE: 11-06-2024

Page 1 of 1

TEST NUMBER: 0312161

<b>CLIENT</b>	Palziv North America
---------------	----------------------

<b>TEST METHOD CONDUCTED</b>	ISO 4918 Resilient, Textile and Laminate Floor Coverings - Castor Chair Test
------------------------------	--

DESCRIPTION OF TEST SAMPLE	
<b>IDENTIFICATION</b>	Rockwater Oak with ECF Underlayment
<b>CONSTRUCTION</b>	Laminate Flooring
<b>BACKING</b>	Pad
<b>REFERENCE</b>	Home Decorators


### GENERAL PRINCIPLE

This test is designed to determine what effect the action of rolling traffic has on a particular flooring surface. The sample is subjected to the reciprocating action of a chair base which is loaded with weight. The chair castors are set to cause a circular cycling motion resulting in a circle shaped wear pattern.

### TEST RESULTS

NUMBER OF CYCLES	APPEARANCE RATING
35,000	No Damage

APPROVED BY:



This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, LLC, shall not be used under any circumstance in advertising to the general public.